

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1733

Dated: 03/02/2026

It is certified that an inspection team headed by Manohar Prasad Sub Engineer from Siwan PHED inspected the **M.S MEMORIAL PUBLIC SCHOOL, AT-BALGANGA,PO-TURKAULIEA, MOTIHARI-845437 (BIHAR)** on 03/02/2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing no 383/26 dated 03/02/2026 of Govt. Water Testing Lab, Motihari (PHED Lab) certified that the **M.S MEMORIAL PUBLIC SCHOOL, AT-BALGANGA,PO- TURKAULIEA, MOTIHARI-845437 (BIHAR)** (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt. This certificate is valid till one year's 03/02/2026 to 02/08/2026



To
The Principal
M.S. MEMORIAL PUBLIC SCHOOL
BALGANGA, TURKAULIEA, MOTIHARI (BIHAR)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Government of Bihar
Public Health Division Motihari
Water Quality Testing Report

Received Sample on date :03/02/2026

District- East Champaran				Testing date - 03/02/2026				Sample Collected by : School Staff								
SL. No.	Block	Location of Source	Type of Source	Parameters tested												
				pH	Turbidity	Total hardness	Calcium	Magnesium	Chloride	Alkalinity	Iron	Nitrate	Sulphate	Fluoride	Arsenic	Total Coll.
1	TURKAULIEA	M.S. MEMO- RIAL PUBLIC SCHOOL	Boring water	-	1	264	72.8	20	30	304	0.18	3.20	8	0.74	-	< 1.1
Desirable Unit				6.5 - 8.5	1	200	75	30	250	200	0.3 mg/l	45 mg/l	200	1.00	0.01 mg/l	-
Maximum Permissible limit in absence of alternate source				NR	5 NTU	600 mg/l	200 mg/l	100 mg/l	1000 mg/l	600 mg/l	1 mg/l	NR	400 mg/l	1.5 mg/l	NR	-

Memo No. - 383/26


Motihari, E. Champaran, Dated -

03/02/2026


Lab Assistant


Chemist




Assistant Engineer
P.H. Division, Motihari
ASSISTANT ENGINEER
PH DIVISION
MOTIHARI, E. CHAMPARAN